# City of Covington Water Quality Report for 2023

# WWW.COVINGTONTN.COM/WATER-OUALITY-DIVISION

#### Is my drinking water safe?

Yes, our water meets all of EPA's health standards. We have conducted numerous tests for over 80 contaminants that may be in drinking water. As you'll see in the chart on the back, we only detected 11 of these contaminants. We found all of these contaminants at safe levels.

## What is the source of my water?

Your water, which is ground water, comes from the Memphis Sand Aquifer. Our goal is to protect our water from contaminants, and we are working with the State to determine the vulnerability of our water source to potential contamination. The Tennessee Department of Environment and Conservation (TDEC) has prepared a Source Water Assessment Program (SWAP) Report for the untreated water sources serving water to this water system. The SWAP Report assesses the susceptibility of untreated water sources to potential contamination. To ensure safe drinking water, all public water systems treat and routinely test their water. Water sources have been rated as reasonably susceptible, moderately susceptible, or slightly susceptible based on geologic factors and human activities in the vicinity of the water source. The City of Covington sources rated as reasonably susceptible to potential contamination.

An explanation of Tennessee's Source Water Assessment Program, the Source Water Assessment summaries, susceptibility scorings and the overall TDEC report to EPA can be viewed online at

https://www.tn.gov/environment/program-areas/wr-water-resources/water-<u>quality/source-water-assessment.html</u> or you may contact the Water System to obtain copies of specific assessments.

A wellhead protection plan is available for your review by contacting Joseph Bloechl at the City of Covington Water Quality Department between 07:30 - 16:00 weekdays at (901)475-4965.

# Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Este informe contiene información muy importante. Tradúscalo o hable con alguien que lo entienda bien.

For more information about your drinking water, please call Joseph Bloechl, Chief Water Operator at (901)475-4965.

# How can I get involved?

Our City Board meets on the second and fourth Tuesdays of each month at 17:30 at City Hall. Please feel free to participate in these meetings.

## Is our water system meeting other rules that govern our operations?

The State and EPA require us to test and report on our water on a regular basis to ensure its safety. We have met all the requirements. Results of unregulated contaminant analysis are available upon reguest. We want you to know that we pay attention to all the rules.

#### Other Information

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water:

- · Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
  - Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or
  - · Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
  - · Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
  - · Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and the Tennessee Department of Environment and Conservation prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

#### Do I Need To Take Special Precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have under-gone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about not only their drinking water, but food preparation, personal hygiene, and precautions in handling infants and pets from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline 800-426-4791 or at http://www.epa.gov/safewater/lead

# Water System Security

Following the events of September 2001, we realize that our customers are concerned about the security of their drinking water. We urge the public to report any suspicious activities at any utility facilities, including treatment plants, tanks, fire hydrants, etc. to 615-896-9022.

### Think before you flush!

Flushing unused or expired medicines can be harmful to your drinking water. Properly disposing of unused or expired medication helps protect you and the environment. Keep medications out of Tennessee's waterways by disposing in one of our permanent pharmaceutical take back bins. There are nearly 100 take back bins located across the state, to find a convenient location please visit: https://tdeconline.tn.gov/rxtakeback/



# **Water Quality Data**

## What does this chart mean?

- MCLG Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- MCL Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.
- MRDL: Maximum Residual Disinfectant Level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for the control of microbial contaminants.
- MRDLG: Maximum residual disinfectant level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- <u>AL</u> Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- Below Detection Level (BDL) laboratory analysis indicates that the contaminant is not present at a level that can be detected.
- Non-Detects (ND) laboratory analysis indicates that the contaminant is not present.
- Parts per million (ppm) or Milligrams per liter (mg/l) explained as a relation to time and money as one part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) or Micrograms per liter explained as a relation to time and money as one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- <u>Picocuries per liter (pCi/L)</u> picocuries per liter is a measure of the radioactivity in water.
- Millirems per year (mrem/yr) measure of radiation absorbed by the body.
- <u>Million Fibers per Liter (MFL)</u> million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.
- <u>Nephelometric Turbidity Unit (NTU)</u> nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- RTCR Revised Total Coliform Rule. This rule went into effect on April 1, 2016 and replaces the MCL for total coliform with a Treatment Technique Trigger for a system assessment.
- <u>TT</u> Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.

Contaminant	Violation Yes/No	Level Found	Range of Detections	Date of Sample	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (RTCR)	NO	ND		2023		0	TT Trigger	Naturally present in the environment
E. coli Bacteria	NO	ND		2023		0	See Footnote 7	Human or animal wastes
Gross Alpha	NO	3.9		2015	PCi/1	0	15	Erosion of natural deposits
Combined radium	NO	0.9		2015	PCi/1	0	5	Erosion of natural deposits
Antimony	NO	ND		2021	ppb	6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic <sup>2</sup>	NO	ND		2021	ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Asbestos	NO	ND		2021	MFL	7	7	Decay of asbestos cement water mains; erosion of natural deposits
Barium	NO	0.029		2021	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium <sup>3</sup>	NO	ND		2021	ppb	4	4	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries

Cadmium	NO	ND	2021	ppb	5	5	Corrosion of galvanized
Cadilliulli	NO	ND	2021	рро		3	pipes; erosion of natural
							deposits; discharge from
							metal refineries; runoff from waste batteries and
							paints
Chromium	NO	ND	2021	ppb	100	100	Discharge from steel and
							pulp mills; erosion of
Copper	NO	90 <sup>th</sup> %	2022	ppm	1.3	AL=1.3	natural deposits  Corrosion of household
Соррег	NO	0.0242	2023	ppiii	1.3	AL-1.3	plumbing systems; erosion
		0.0212					of natural deposits;
							leaching from wood
Cyanide	NO	0.009	2021	ppb	200	200	preservatives Discharge from steel/metal
Cyamac	NO	92	2021	ppo	200	200	factories; discharge from
		92					plastic and fertilizer
Fluoride	NO	0.60	2022		4	4	factories  Erosion of natural deposits;
riuoride	NO	0.62	2023	ppm	4	4	water additive which
		Avg.					promotes strong teeth;
							discharge from fertilizer
Lead <sup>4</sup>	NO	90 <sup>th</sup> %	2022	ppb	0	AL=15	and aluminum factories  Corrosion of household
Lead	NO	1	2023	рро		AL-13	plumbing systems, erosion
							of natural deposits
Mercury (inorganic)	NO	ND	2021	ppb	2	2	Erosion of natural deposits;
							discharge from refineries and factories; runoff from
							landfills; runoff from
							cropland
Nickel	NO	ND	2021	Ppb	100	100	
Nitrate (as Nitrogen) <sup>5</sup>	NO	ND	2023	ppm	10	10	Runoff from fertilizer use;
							leaching from septic tanks, sewage; erosion of natural
							deposits
Selenium	NO	ND	2021	ppb	50	50	Discharge from petroleum
							and metal refineries; erosion of natural deposits;
							discharge from mines
Sodium	NO	7.57	2021	ppm	N/A	N/A	Erosion of natural deposits;
							used in water treatment
Thallium	NO	ND	2021	ppb	0.5	2	Leaching from ore- processing sites; discharge
							from electronics, glass, and
							drug factories
Alachlor	NO	ND	2022	ppb	0	2	Runoff from herbicide used on row crops
Atrazine	NO	ND	2022	ppb	3	3	Runoff from herbicide used
D.				5.1			on row crops
Benzene	NO	ND	2021	Ppb	0	5	Discharge from factories; leaching from gas storage
							tanks and landfills
Carbon tetrachloride	NO	ND	2021	ppb	0	5	Discharge from chemical
							plants and other industrial
Chlorobenzene	NO	ND	2021	ppb	100	100	activities Discharge from chemical
Carologonzene	NO	שאו	ZUZ I	PPO	100	100	and agricultural chemical
5.11					1		factories
o-Dichlorobenzene	NO	ND	2021	ppb	600	600	Discharge from industrial chemical factories
							CHEHHCAI TACIOTIES

p-Dichlorobenzene	NO	ND	2021	ppb	75	75	Discharge from industrial chemical factories
1,2 - Dichloroethane	NO	ND	2021	ppb	0	5	Discharge from industrial chemical factories
1,1 - Dichloroethylene	NO	ND	2021	ppb	7	7	Discharge from industrial chemical factories
cis-1,2- Dichloroethylene	NO	ND	2021	ppb	70	70	Discharge from industrial chemical factories
trans - 1,2 - Dichloroethylene	NO	ND	2021	ppb	100	100	Discharge from industrial chemical factories
Dichloromethane	NO	ND	2021	ppb	0	5	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane	NO	ND	2021	ppb	0	5	Discharge from industrial chemical factories
Ethylbenzene	NO	ND	2021	ppb	700	700	Discharge from petroleum refineries
Styrene	NO	ND	2021	ppb	100	100	Discharge from rubber and plastic factories; leaching from landfills
Tetrachloroethylene	NO	ND	2021	ppb	0	5	Discharge from factories and dry cleaners
1,2,4 - Trichlorobenzene	NO	ND	2021	ppb	70	70	Discharge from textile- finishing factories
1,1,1 - Trichloroethane	NO	ND	2021	ppb	200	200	Discharge from metal degreasing sites and other factories
1,1,2 - Trichloroethane	NO	ND	2021	ppb	3	5	Discharge from industrial chemical factories
Trichloroethylene	NO	ND	2021	ppb	0	5	Discharge from metal degreasing sites and other factories
TTHM <sup>6</sup> [Total trihalomethanes]	NO	7.28	2023	ppb	n/a	80	By-product of drinking water chlorination
Haloacetic Acids (HAA5)	NO	1.82	2023	ppb	N/A	60	By-product of drinking water disinfection.
Toluene	NO	ND	2021	ppm	1	1	Discharge from petroleum factories
Vinyl Chloride	NO	ND	2021	ppb	0	2	Leaching from PVC piping; discharge from plastics factories
Xylenes	NO	ND	2021	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories

Contaminant	Violation Yes/No	Level Found	Range of Detections	Date of Sample	Unit Measurement	MRDLG	MRDL	Likely Source of Contamination
Chlorine	NO	1.48	0-4.0	2023	ppm	4	4	Water additive used to control microbes.

**Iron:** Iron occurs naturally in our raw water and occasionally accumulates in the distribution system. Iron shows up as "red" or "rusty" water at your tap. Although you do not want to drink water that is not clear, iron is not considered to be a hazard to your health. We test for iron daily and it is usually around 0 ppm. The aesthetic limit for iron is 0.3 ppm.

During the most recent round of Lead and Copper testing, 0 out of 33 households sampled contained concentrations exceeding the action level.

<sup>2</sup>While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to

<sup>&</sup>lt;sup>1</sup>100% of our samples were below the turbidity limit.

research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

<sup>3</sup>The laboratory did not meet the required detection limit therefore the data does not necessarily reflect that the water is contaminated to a level approaching the MCL.

<sup>4</sup>Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (1-800-426-4791).

<sup>5</sup>Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

<sup>6</sup> While your drinking water meets EPA's standard for trihalomethanes, it does contain low levels. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

<sup>7</sup>E. coli: A system is in compliance with the MCL for E. coli for samples unless any of the conditions identified in parts 1 through 4 occur.

- 1. The system has an E. coli-positive repeat sample following a total coliform positive routine sample.
- 2. The system has a total coliform positive repeat sample following an E. coli-positive routine sample.
- 3. The system fails to take all required repeat samples following an E. coli-positive routine sample.
- 4. The system fails to test for E. coli when any repeat sample tests positive for total coliform.

The following actions have been taken to correct the violation listed in the above table for Total Coliform Bacteria:

1. Resampled following the State guidelines

# **Health Effects**

#### Microbiological Contaminants:

Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems. Fecal coliform/E.Coli. Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems. Turbidity. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. *Radioactive Contaminants:* 

Beta/photon emitters. Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta and photon emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Alpha emitters. Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Combined Radium 226/228. Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.

Inorganic Contaminants:

Antimony. Some people who drink water containing antimony well in excess of the MCL over many years could experience increases in blood cholesterol and decreases in blood sugar.

Arsenic. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

Asbestos. Some people who drink water containing asbestos in excess of the MCL over many years may have an increased risk of developing benign intestinal polyps.

Barium. Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.

Beryllium. Some people who drink water containing beryllium well in excess of the MCL over many years could develop intestinal lesions.

Cadmium. Some people who drink water containing cadmium in excess of the MCL over many years could experience kidney damage.

Chromium. Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.

Copper. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Cyanide. Some people who drink water containing cyanide well in excess of the MCL over many years could experience nerve damage or problems with their thyroid.

Fluoride. Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Children may get mottled teeth.

Lead. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Mercury (inorganic). Some people who drink water containing inorganic mercury well in excess of the MCL over many years could experience kidney damage.

Nitrate. Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.

Nitrite. Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.

Selenium. Selenium is an essential nutrient. However, some people who drink water containing selenium in excess of the MCL over many years could experience hair or fingernail losses, numbness in fingers or toes, or problems with their circulation.

Thallium. Some people who drink water containing thallium in excess of the MCL over many years could experience hair loss, changes in their blood, or problems with their kidneys, intestines, or liver.

Synthetic organic contaminants including pesticides and herbicides:

2,4-D. Some people who drink water containing the weed killer 2,4-D well in excess of the MCL over many years could experience problems with their kidneys, liver, or adrenal glands.

2,4,5-TP (Silvex). Some people who drink water containing silvex in excess of the MCL over many years could experience liver problems.

Acrylamide. Some people who drink water containing high levels of acrylamide over a long period of time could have problems with their nervous system or blood, and may have an increased risk of getting cancer.

Alachlor. Some people who drink water containing alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or experience anemia, and may have an increased risk of getting cancer.

Atrazine. Some people who drink water containing atrazine well in excess of the MCL over many years could experience problems with their cardiovascular system or reproductive difficulties.

Benzo(a)pyrene [PAH]. Some people who drink water containing benzo(a)pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.

Carbofuran. Some people who drink water containing carbofuran in excess of the MCL over many years could experience problems with their blood, or nervous or reproductive systems.

Chlordane. Some people who drink water containing chlordane in excess of the MCL over many years could experience problems with their liver or nervous system, and may have an increased risk of getting cancer.

Dalapon. Some people who drink water containing dalapon well in excess of the MCL over many years could experience minor kidney changes.

Di (2-ethylhexyl) adipate. Some people who drink water containing di (2-ethylhexyl) adipate well in excess of the MCL over many years could experience general toxic effects or reproductive difficulties.

Di (2-ethylhexyl) phthalate. Some people who drink water containing di (2-ethylhexyl) phthalate in excess of the MCL over many years may have problems with their liver, or experience reproductive difficulties, and may have an increased risk of getting cancer. Dibromochloropropane (DBCP). Some people who drink water containing DBCP in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.

Dinoseb. Some people who drink water containing dinoseb well in excess of the MCL over many years could experience reproductive difficulties.

Dioxin (2,3,7,8-TCDD). Some people who drink water containing dioxin in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.

Diquat. Some people who drink water containing diquat in excess of the MCL over many years could get cataracts.

Endothall. Some people who drink water containing endothall in excess of the MCL over many years could experience problems with their stomach or intestines.

Endrin. Some people who drink water containing endrin in excess of the MCL over many years could experience liver problems. Epichlorohydrin. Some people who drink water containing high levels of epichlorohydrin over a long period of time could experience stomach problems, and may have an increased risk of getting cancer.

Ethylene dibromide. Some people who drink water containing ethylene dibromide in excess of the MCL over many years could experience problems with their liver, stomach, reproductive system, or kidneys, and may have an increased risk of getting cancer. Glyphosate. Some people who drink water containing glyphosate in excess of the MCL over many years could experience problems with their kidneys or reproductive difficulties.

Heptachlor. Some people who drink water containing heptachlor in excess of the MCL over many years could experience liver damage and may have an increased risk of getting cancer.

Heptachlor epoxide. Some people who drink water containing heptachlor epoxide in excess of the MCL over many years could experience liver damage, and may have an increased risk of getting cancer.

Hexachlorobenzene. Some people who drink water containing hexachlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys, or adverse reproductive effects, and may have an increased risk of getting cancer. Hexachlorocyclopentadiene. Some people who drink water containing hexachlorocyclopentadiene well in excess of the MCL over many years could experience problems with their kidneys or stomach.

Lindane. Some people who drink water containing lindane in excess of the MCL over many years could experience problems with their kidneys or liver.

Methoxychlor. Some people who drink water containing methoxychlor in excess of the MCL over many years could experience reproductive difficulties.

Oxamyl [Vydate]. Some people who drink water containing oxamyl in excess of the MCL over many years could experience slight nervous system effects.

PCBs [Polychlorinated biphenyls]. Some people who drink water containing PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland, immune deficiencies, or reproductive or nervous system difficulties, and may have an increased risk of getting cancer.

Pentachlorophenol. Some people who drink water containing pentachlorophenol in excess of the MCL over many years could experience problems with their liver or kidneys, and may have an increased risk of getting cancer.

Picloram. Some people who drink water containing picloram in excess of the MCL over many years could experience problems with their liver.

Simazine. Some people who drink water containing simazine in excess of the MCL over many years could experience problems with their blood.

Toxaphene. Some people who drink water containing toxaphene in excess of the MCL over many years could have problems with their kidneys, liver, or thyroid, and may have an increased risk of getting cancer.

Volatile Organic Contaminants:

Benzene. Some people who drink water containing benzene in excess of the MCL over many years could experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.

Carbon Tetrachloride. Some people who drink water containing carbon tetrachloride in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.

Chlorobenzene. Some people who drink water containing chlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys.

o-Dichlorobenzene. Some people who drink water containing o-dichlorobenzene well in excess of the MCL over many years could experience problems with their liver, kidneys, or circulatory systems.

p-Dichlorobenzene. Some people who drink water containing p-dichlorobenzene in excess of the MCL over many years could experience anemia, damage to their liver, kidneys, or spleen, or changes in their blood.

- 1,2-Dichloroethane. Some people who drink water containing 1,2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer.
- 1,1-Dichloroethylene. Some people who drink water containing 1,1-dichloroethylene in excess of the MCL over many years could experience problems with their liver.
- cis-1,2-Dichloroethylene. Some people who drink water containing cis-1,2-dichloroethylene in excess of the MCL over many years could experience problems with their liver.
- trans-1,2-Dicholoroethylene. Some people who drink water containing trans-1,2-dichloroethylene well in excess of the MCL over many years could experience problems with their liver.

Dichloromethane. Some people who drink water containing dichloromethane in excess of the MCL over many years could have liver problems and may have an increased risk of getting cancer.

1,2-Dichloropropane. Some people who drink water containing 1,2-dichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.

Ethylbenzene. Some people who drink water containing ethylbenzene well in excess of the MCL over many years could experience problems with their liver or kidneys.

Styrene. Some people who drink water containing styrene well in excess of the MCL over many years could have problems with their liver, kidneys, or circulatory system.

Tetrachloroethylene. Some people who drink water containing tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.

- 1,2,4-Trichlorobenzene. Some people who drink water containing 1,2,4-trichlorobenzene well in excess of the MCL over many years could experience changes in their adrenal glands.
- 1,1,1,-Trichloroethane. Some people who drink water containing 1,1,1-trichloroethane in excess of the MCL over many years could experience problems with their liver, nervous system, or circulatory system.
- 1,1,2-Trichloroethane. Some people who drink water containing 1,1,2-trichloroethane well in excess of the MCL over many years could have problems with their liver, kidneys, or immune systems.

Trichloroethylene. Some people who drink water containing trichloroethylene in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.

TTHMs [Total Trihalomethanes]. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. HAA [Haloacetic Acids]. Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

Toluene. Some people who drink water containing toluene well in excess of the MCL over many years could have problems with their nervous system, kidneys, or liver.

Uranium. Some people who drink water containing uranium in excess of the MCL over many years may have an increased rick of getting cancer and kidney toxicity.

Vinyl Chloride. Some people who drink water containing vinyl chloride in excess of the MCL over many years may have an increased risk of getting cancer.

Xylenes. Some people who drink water containing xylenes in excess of the MCL over many years could experience damage to their nervous system.